



ANDHRA PRADESH ELECTRICITY REGULATORY COMMISSION

Vidyut Niyantrana Bhavan, Adjacent to 220/132/33/11 kV, AP Carbides Sub Station,
Dinnedevaram Road, Kurnool - 518 002, Andhra Pradesh
Phones: 08518 - 294823, 294824, 294825, 294826

APERC - Regulation 4 of 2023 - Technical feasibility for grid-interactive Solar rooftop photovoltaic systems - Waiver up to 10 kW contract load - Orders - Issued - Reg.

Proceedings. No.8 of 2024 /T-C/TAM/

Date: 10-06-2024

Read the following:

Order

APCPDCL and APEPDCL have requested instructions from the Commission on waiving technical feasibility for SRT installations up to 10 kW capacity as per MoP Rules. APSPDCL has requested an amendment to Regulation 4 of 2023 for the same.

After examining the request in detail and the GoAP and GoI's aim to promote the installation of SRTs under the PM Surya Ghar Programme in the State of Andhra Pradesh, exercising the powers under clauses 18 (Power to Relax) & 20 (Power to Remove difficulties) of Regulation 4 of 2023, the Commission hereby issues the following Order.

“Clause 12 of Regulation 4 of 2023 is relaxed, and the DISCOMS shall process the applications for installation of SRTs from the consumers up to 10 kW contracted load without any technical feasibility provided that cumulative installation of SRTs under DTR shall not exceed the percentage of DTR capacity as specified in clause 5.8 of the Regulation.”

(By order of the Hon'ble Commission)

Commission Secretary (i/c)

To

The Chairman & Managing Director, APCPDCL, Vijayawada.

The Chairman & Managing Director, APEPDCL, Visakhapatnam.

The Chairman & Managing Director, APSPDCL, Tirupati.

Copy to the Special Chief Secretary, Energy Department, GoAP, Amaravathi